

LINN COUNTY PARKS & RECREATION

3010 FERRY STREET SW, ALBANY, OREGON, 97321
TELEPHONE: (541) 967-3917 FAX: (541) 924-6915



March 6, 2019

ADDENDUM NO. 2
ITB NO. 19-01
STAYTON BRIDGE BOAT RAMP CONSTRUCTION PROJECT
BIDS DUE: MARCH 11, 2019 BY 5:00 PM LOCAL TIME

The Invitation to Bid (ITB) listed above is modified as set forth in this Addendum. The original ITB Documents and any previously issued addenda remain in full force and effect, except as modified by this Addendum, which is hereby made part of the ITB. Offerors shall take this Addendum into consideration when preparing and submitting its bid.

AMENDMENTS		
Item No.	Location	Change
2.0	New Exhibit I	ITB amended to include Hydraulic Analysis Report: A Hydraulic Analysis Report for the Project Site has been added as Exhibit I to the ITB.
2.1	Page 4, Section C.6 Forms Required	The bullet "Payment and Performance Bonds" provided under Section C.6 is hereby deleted. Payment and performance bonds are only required to be submitted by the successful bidder after the contract has been awarded, as correctly provided in Section I.2 of the ITB.

ADDITIONAL CLARIFICATIONS		
Item No.	Location	Q&A
2.0	N/A	<p>Question: <i>Is it acceptable to construct a temporary cofferdam (i.e. sandbag structure) to help with in-water construction activities?</i></p> <p>County Response: A temporary structure (i.e. jetty, sand bags, etc.) could be constructed to help with deflecting the river flow during construction. Any temporary structure will require 100 percent removal at the end of construction. As currently permitted, it is not possible to create a closed cofferdam, dewater, and work in the dry.</p>
2.1	Page 3, Section B.5.5 Clarifications, Objections, and Questions	<p>This will be the final Addendum issued for this ITB. No additional questions will be accepted prior to closing.</p>

END OF ADDENDUM